

Equipment and Protective Systems for use in **Potentially Explosive Atmospheres**

Health & Safety Briefing No. 23

May 2012



Health and safety

(Name of company)

Our statement of general policy

- to provide adequate control
- activities;
- to consult with
- to provide and
- to ensure safety

Principles

Did you know that...

A Boeing 737, spray-painting and a gas storage area all have something in common? They all can give rise to a potentially explosive atmosphere that requires special precautions to be taken with electrical and mechanical equipment.

Where flammable liquids, gases, mists or combustible dusts are stored or used then provision has to be made to prevent the possibility of release of these materials. This is normally done by the design of the process containment.

However, there may well be situations where releases can occur in the presence of air and these will give rise to potentially explosive atmospheres. Such areas are known as hazardous areas.

To assist the user a system called area classification defines three zones indicating the likelihood of the presence of a potentially explosive atmosphere based on the frequency and duration of any release. The area outside the zoned area is non-hazardous. The assessment of area classification would usually be done by a process or chemical engineer working with a control and electrical engineer and the person responsible for the operational management of the plant. One of the assessment team should be experienced in the technique of area classification.

Following the completion of the area classification the user can then select electrical and mechanical equipment, with protection against the likelihood of becoming ignition capable and appropriate to the zone. When the zone and the appropriate level of protection are considered together, an acceptable level of safety is achieved.

Ideally sources of ignition such as arcs and hot surfaces should be excluded from hazardous areas to prevent the possibility of an explosion. Wherever possible equipment should be installed where the area is non-hazardous. If it is essential that equipment be installed in hazardous areas the equipment should be designed and constructed to ensure that any risk of it causing an ignition is acceptably low. Where new electrical and mechanical equipment is to be provided this should conform with local regulations for equipment to be used in any of the hazardous zones.

UK Legislation and Implementation

Where new electrical and mechanical equipment is to be provided to work within the hazardous zones this should conform with "The Equipment and Protective Systems Intended for Use in Potentially Explosive Atmospheres Regulations 1996 - Statutory Instrument 1996/192".

Following the introduction of the **D**angerous **S**ubstances and **E**xplosive **A**tmospheres **R**egulations (DSEAR) in July 2003 area classification is now a requirement under these Regulations. DSEAR also requires, where necessary, the provision of a sign to mark places, which have been classified as hazardous places. The Regulations require a risk assessment to identify all other sources of ignition including existing equipment. Guidance on area classification and methods of protection for equipment are contained in British, European and International standards.

References

- The Equipment and Protective Systems Intended for Use in Potentially Explosive Atmospheres Regulations 1996: Statutory Instrument (S.I.) 1996 No.192, HMSO, 1996, see http://www.opsi.gov.uk/si/si1996/uksi_19960192_en_1.htm
- Dangerous Substances and Explosive Atmospheres Regulations 2002 (SI 2002/2776) (DSEAR) ISBN 0110429575 published by The Stationery Office Ltd. Tel: 0870 600 5522, <http://www.opsi.gov.uk/si/si2002/20022776.htm>
- BS EN 60079-10: 2003: Electrical apparatus for explosive gas atmospheres. Classification of hazardous areas: BSI, 2003, ISBN 0580417360
- BS EN 50281-3:2002: Equipment for use in the presence of combustible dust - Part 3: Classification of areas where combustible dusts are or may be present, ISBN 0580406024
- A harmonised European standard for category 3 mechanical equipment is now available as BS EN 13463 series standards

These Briefings contain a summary of recent Health & Safety issues, provided for general information purposes only, and should not be relied upon as legal advice. The IET has tried to make the Briefings accurate and informative, but they have not been prepared by a lawyer and may not constitute an up-to-date summary of the law. The IET accepts no liability for your use of these Briefings. Further details and information on broader Health & Safety issues can be obtained from the Government's Health and Safety Executive. Legal advice should be obtained on any specific issues.



For further information about the IET's Health and Safety Policy Advisory Group only, please contact:

Health and Safety Policy Advisory Group Secretary
Policy Department
IET,
Michael Faraday House,
Six Hills Way,
Stevenage.
SG1 2AY
01438 765690
email: policy@theiet.org
www.theiet.org/policy
www.theiet.org/factfiles

© The IET 2012

The Institution of Engineering and Technology is registered as a Charity in England & Wales (no 211014) and Scotland (no SC038698).